

City of El Paso - City Plan Commission Staff Report

Case No: SUSU12-00092 Ventanas Subdivision Unit Six

Application Type: Major Final **CPC Hearing Date:** October 18, 2012

Staff Planner: Justin Bass, 915-541-4930, <u>bassjd@elpasotexas.gov</u>
Location: North of Ventana Ave and West of Rich Beem Blvd

Legal Description Acreage: 36.518 acres

Rep District: 6

Existing Use: Vacant

Existing Zoning: R-5 (Residential) **Proposed Zoning:** R-5 (Residential)

Nearest School: Lujan Chavez Elementary School (1.49 miles)

Note: The Ventanas Land Study - which includes this subdivision - identifies a future school site directly south

of this subdivision.

Nearest Park: Unnamed Park (0.16-mile)

Parkland Fees Required: N/A

Impact Fee Area: This property is not located within an Impact Fee Service

Area and is not subject to impact fees.

Property Owner: GFA, LLC Applicant: CEA Group **Representative:** CEA Group

SURROUNDING ZONING AND LAND USE

North: ETJ/ Vacant

South: R-5 (Residential) & C-1 (Commercial)/ Vacant

East: R-5 (Residential)/ Single Family Residential Development

West: R-5 (Residential)/ Vacant

PLAN EL PASO DESIGNATION: G4 Suburban (Walkable).

APPLICATION DESCRIPTION

The applicant is proposing a subdivision that will include 218 single-family residential lots. The smallest lot will measure approximately 5,303 square feet in size and the largest approximately 7,951 square feet in size. Primary access to the development is proposed from both Ventana Avenue and Rich Beem Boulevard.

The applicant is requesting the following modifications:

• To allow for the reduction of street right-of-way from 52-ft to 50-ft. The cross-section

SUSU12-00092 1 October 18, 2012

- will consist of 5-ft sidewalks, 5-ft parkways, and 30-ft of pavement, with a standard concrete curb and gutter.
- To allow for the reduction of street right-of-way from 52-ft to 48-ft. The cross-section will consist of 5-ft sidewalks, 5-ft parkways, and 28-ft of pavement, with a standard concrete curb and gutter.
- To allow for a street name longer than 13 characters.

The property is part of the Ventanas Land Study that was approved by the City Plan Commission on December 21, 2006. This application has been granted a vesting rights petition in part making the development subject to the subdivision ordinance in effect prior to June 1, 2008. The applicant will apply one section from the new subdivision ordinance, Section 19.08.010, allowing the developer's engineer to design the water and wastewater plans. Aside from this one section, the subdivision is subject to the prior subdivision ordinance.

CASE HISTORY

Ventanas Subdivision Unit Six was approved on a major preliminary basis on August 9, 2012, with the following modifications:

- To allow for the reduction of street right-of-way from 52-ft to 50-ft. The cross-section will consist of 5-ft sidewalks, 5-ft parkways, and 30-ft of pavement, with a standard concrete curb and gutter.
- To allow for the reduction of street right-of-way from 52-ft to 48-ft. The cross-section will consist of 5-ft sidewalks, 5-ft parkways, and 28-ft of pavement, with a standard concrete curb and gutter.
- To allow for a street name longer than 13 characters.

And subject to the following condition:

• The City Plan Commission requires the applicant to landscape the parkway area on Rich Beem Boulevard, as stipulated under Section 19.16.080(D) The city plan commission may require that a parkway at the rear of a double frontage lot be landscaped or other aesthetic treatment be provided by the subdivider, subject to the approval of the planning & economic development director or designee, to provide visual separation between the development and the street. The condition should be coordinated with the El Paso Department of Transportation where it conflicts with site visibility standards, utilities, and parkway illumination. For the type of landscaping, staff recommends the developer select trees designated as median/street/right of way appropriate from the City's Plant and Tree List, to be placed 30-feet on centers.

DEVELOPMENT COORDINATING COMMITTEE COMMENTS:

The Development Coordinating Committee recommends *approval* of the modifications under Reason 3 of Section 19.04.170.A of the previous Subdivision Ordinance and *approval* of Ventanas Subdivision Unit Six on a **Major Final** basis subject to the following conditions and requirements:

Staff is also recommending that the City Plan Commission require the applicant to landscape the parkway area on Rich Beem Boulevard, as stipulated under Section 19.16.080(D) *The city plan commission may require that a parkway at the rear of a double frontage lot be landscaped or other aesthetic treatment be provided by the subdivider, subject to the approval of the planning*

SUSU12-00092 2 October 18, 2012

& economic development director or designee, to provide visual separation between the development and the street. Staff also recommends that if the City Plan Commission requires landscaping, that the condition be coordinated with the El Paso Department of Transportation where it conflicts with site visibility standards, utilities, and parkway illumination. For the type of landscaping, staff recommends the developer select trees designated as median/street/right of way appropriate from the City's Plant and Tree List, to be placed 30-feet on centers.

Planning Division Recommendation:

Approval with modifications. In this case, the subdivider has demonstrated an alternative method of development that will improve the aesthetic value of the subdivision while giving equal emphasis to safety, economy, tax yield, maintenance cost, response time, drainage, vehicular access and pedestrian passage.

Transportation

The subdivision was reviewed utilizing the previous version of Title 19 of the El Paso City Code.

Notes:

- Double frontage lots along Rich Beem Boulevard shall comply with Section 19.16.080.D (Double Frontage Lots).
- All existing and/or proposed paths of travel (accessible sidewalks, wheelchair access curb ramps and driveways) within public rights-of-way shall follow the City of El Paso Design Standards for Construction and be ADA/TAS compliant.

City Development Department - Land Development

We have reviewed subject plan recommend **Approval**; Developer/Engineer needs to address the following comments:

1. The improvements plan must comply with 19-08-080 of the El Paso Municipal Code.

Parks and Recreation Department

We have reviewed <u>Ventanas #6</u>, a major final plat map and <u>offer no objections</u> to this subdivision application.

Please note that this Subdivision is composed of <u>218</u> Single-family dwelling lots and does not include a park site, however, applicant has dedicated four (4) Off-site Parks as shown in the location map as not part of this subdivision (Ventanas Cove: Tract 1C, Ventanas Destiny: Tract 1D, Ventanas Willow: Tract 1E, and Tract 1F: Still not platted) as part of the Ventanas Land Study & as part of a Developer's Agreement; therefore, meeting the "Parkland" requirements of Title 19 – Subdivision & Development Plats, Chapter 19.20 – Parks & Open Space.

Please note that Ventanas Cove Park (Ventanas #1) & Ventanas Destiny Park (Ventanas #2)have been constructed and accepted by this Department for maintenance; also park improvement plans for Ventanas Willow Park (Ventanas #3) have been approved on August 02, 2012

Also, please provide a revised estimated completion date letter for Ventanas Willow Park and for Ventanas Park #4.

El Paso Water Utilities

We have reviewed the subdivision described above and provide the following comments:

SUSU12-00092 3 October 18, 2012

- 1. There is an existing 24-inch diameter water main along Ventana Avenue from Amistoso Street to Rich Beem Boulevard. Also, there is an existing 12-inch diameter water main along Rich Beam Boulevard north of Ventana Avenue.
- 2. There is an existing 15-inch diameter sanitary sewer main along Ventana Avenue from Amistoso Street to Rich Beem Boulevard.
- 3. Water and sewer service for the subdivision requires extensions from the proposed water and sewer mains within Ventanas Unit 4. Twelve (12) inch diameter water main extensions are required along Lost Willow Avenue and Fox Grove Street.
- 4. Annexation fees are due at the time of new service application for individual water meters within the subject subdivision.
- 5. EPWU-PSB requires a new service application to serve the subdivision. New service applications should be made 6-8 weeks in advance of construction to ensure water for construction work. The following items, if applicable, are required at the time of application: (1) hard copy of site plan with street names and addresses; (2) finalized set of improvement plans, including grading & drainage plans; (3) digital copy of site plan; (4) benchmark check; (5) construction schedule; and (6) a certificate of compliance. Service will be provided in accordance with the current El Paso Water Utilities Public Service Board (EPWU-PSB) Rules and Regulations. The owner is responsible for the costs of any necessary on-site and off-site extensions, relocations or adjustments of water and sanitary sewer lines and appurtenances.

Sun Metro

Sun Metro recommends the placement of sidewalks throughout the development to City standards to provide pedestrian accessibility to mass transit services.

El Paso Fire Department

No comments received.

911

No comments received.

Central Appraisal District

No comments received.

El Paso Electric Company

No comments received.

Texas Gas Company

No comments received.

Socorro Independent School District

No comments received.

Additional Requirements and General Comments:

- 1. Submit to the City Development Department Planning Division the following prior to recording of the subdivision.
 - a. Current certified tax certificate(s)
 - b. Current proof of ownership
 - c. Release of access document, if applicable
 - d. Set of restrictive covenants, if applicable


SUSU12-00092 4 October 18, 2012

2. Every subdivision shall provide for postal delivery service. The subdivider shall coordinate the installation and construction with the United States Postal Service in determining the type of delivery service for the proposed subdivision. In all cases, the type and location of delivery service shall be subject to the approval of the United States Postal Service.

Attachments


- 1. Location map
- 2. Aerial map
- 3. Final plat
- 4. Cross-sections
- 5. Modification request
- 6. Application


SUSU12-00092 5 October 18, 2012



ATTACHMENT 1









Castner Center @ Transmountain 4712 Woodrow Bean, Ste. F El Paso, TX 79924 Office: 915.544.5233 Fax: 915.544.5233 web: www.ceagroup.net

October 1, 2012

City of El Paso-City Development Department Two Civic Center Plaza-5th Floor El Paso, Texas 79901

Attention:

Mr. Justin Bass

Subdivision Planner

Reference:

Ventanas Subdivision Unit Six

Variance Request

Dear Mr. Bass:

On behalf of the developer for the above referenced development, we request three (3) variances to the City of El Paso Municipal Code-Subdivision Ordinance. Our variance requests are as follows:

- Reduce the residential sub-collector right-of-way from 52-feet to 50-feet. Our proposed cross-section will introduce 5 foot sidewalk and 5 foot parkway and a 30 foot paved roadway surface and utilize standard concrete curb and gutter.
- Reduce the residential sub-collector right-of-way from 52-feet to 48-feet. Our proposed cross-section will introduce 5 foot sidewalk and 5 foot parkway and a 28 foot paved roadway surface and utilize standard concrete curb and gutter.
- Allow for street name longer than 13 characters.

We look forward to your favorable consideration on our request. If you have any questions, please do not hesitate to call me at office number 915.544.5232 or mobile number 915.355.0583.

Sincerely,

CEA Group

Jorge L. Azcarate, P.E. Project Manager

I-2260-016ld.eg.1October12(modificationreq).doc JLA/jla

engineers • architects • planners

SUSU12-00092 10 October 18, 2012





CITY PLAN COMMISSION APPLICATION FOR MAJOR SUBDIVISION FINAL APPROVAL

		2. Texas and Pacific Railroad Surve	
Property Land Uses:			
	ACRES SITES	Office	ACRES SITES
Single-family	<u>28.357</u> <u>218</u>	Street & Alley	8.161 7.
Duplex		Ponding & Drainage	0.101
Apartment		Institutional	
Mobile Home P.U.D.		Other (specify below)	
P.O.D. Park		Other (specify below)	
School			
Commercial		Total No. Sites	225 .
Industrial		Total (Gross) Acreage	36.518 .
Will the residential s		erty?R-5Proposed z pment in full compliance with all zo No	
Will the residential sexisting residential ze. What type of utility of drainage.	ites, as proposed, permit develoone(s)? Yes_X_ easements are proposed: Under	pment in full compliance with all zon No rground Overhead Con ist more than one)	ning requirements of the
Will the residential s existing residential z What type of utility of What type of drainag Surface flow to pro	ites, as proposed, permit develo one(s)? Yes_X_ easements are proposed: Under the is proposed? (If applicable, leading to the posed inlets at storm sewer infr	pment in full compliance with all zon No rground Overhead Con	ning requirements of the abination of Both_X_retention basin
Will the residential s existing residential z What type of utility of What type of drainag Surface flow to pro- located at Ventana	ites, as proposed, permit develoone(s)? Yes_X_ casements are proposed: Under the is proposed? (If applicable, legosed inlets at storm sewer infrest Subdivision Unit Four.	pment in full compliance with all zon No rground Overhead Con ist more than one) astructure discharging to an existing	ning requirements of the abination of Both_X_
Will the residential sexisting residential zexisting residential zexisting residential zexisting residential zexisting residential zero what type of drainages Surface flow to propose located at Ventanas. Are special public in Is a modification or of If answer is "Yes", p	ites, as proposed, permit develoone(s)? Yes_X_ casements are proposed: Under the is proposed? (If applicable, It posed inlets at storm sewer infrest Subdivision Unit Four. Approvements proposed in connect acception of any portion of the selease explain the nature of the response.	pment in full compliance with all zon No rground Overhead Con ist more than one) astructure discharging to an existing	ning requirements of the abination of Both_X_ retention basin
Will the residential sexisting residential zewisting residential zewhat type of drainage Surface flow to prolocated at Ventana: Are special public in Is a modification or of If answer is "Yes", per Modification Reque	ites, as proposed, permit develo	pment in full compliance with all zon No rground Overhead Con ist more than one) astructure discharging to an existing ction with development? Yes Subdivision Ordinance proposed? nodification or exception	retention basin NoX YesX No

12.	Owner of record GFA LLC.	x. 79936 (915) 548-1105				
	(Name & Addre	35)	(Zip)	(Phone)		
12.	Developer Same as above			8		
	(Name & Addre	ss)	(Zip)	(Phone)		
14.	Engineer CEA Group 4712 Woodrow Bean Ste. F, El Paso Tx. 79924 (915) \$44-5232					
	(Name & Addre	ss)	(Zip)	(Phone)		
		· ·	Man YM			
	CASHIER'S VALIDATION	OWNER SIGNATURE:				
	FEE: \$1,796.00	REPRESENTATIVE:	A Too			
		REPRESENTATIVE.				

NOTE: SUBMITTAL OF AN APPLICATION DOES NOT CONSTITUTE ACCEPTANCE FOR PROCESSING UNTIL THE PLANNING DEPARTMENT REVIEWS THE APPLICATION FOR ACCURACY AND COMPLETENESS.